

SS 12.1 - Audio Loops

Address:			
Provided by (name):			
Equipment Register			
	Make	Model	Location
1			
2			
3			
4			
Performance/Installation Standard:	<input type="checkbox"/> AS 1088.4:1987 <input type="checkbox"/> Specifically Designed Alternate Solution <input type="checkbox"/> Other (Historical) _____		
Inspections & Maintenance Standard:	<input type="checkbox"/> Compliance Schedule Handbook and AS 1088.4:1987 <input type="checkbox"/> Specifically designed solution provide details separately		
As a minimum these inspections and maintenance procedures will be carried out:	Planned preventative maintenance and responsive maintenance will be carried out in accordance with the nominated performance and inspection standard or document to ensure the system will operate as required. See Below		
Inspection frequency and responsibility:	<input type="checkbox"/> Six -monthly	<input type="checkbox"/> Owner <input type="checkbox"/> IQP	
	<input type="checkbox"/> Monthly	<input type="checkbox"/> Owner <input type="checkbox"/> IQP	
<i>Six-monthly Inspections</i>	<ul style="list-style-type: none"> • Magnetic field strength in the specified magnetic field area for the values defined in AS 1088.4:1987 • Magnetic background noise interference from other equipment where, since the last inspection, equipment has been installed, activated or altered in the proximity of the teleloop system. • (such equipment could include electrical fittings, heating systems, electrical controls or equipment, an adjacent loop system or metallic structure). • Sound amplification installations consisting of loop systems should be tested for sound pressure and sound distortion. • Where room acoustics have been altered since the last inspection, the sound amplification should also be tested for spectrum analysis and speech intelligibility (RASTI), (Room acoustics could have been altered or affected by such things as removing carpet, curtains or objects). 		
Reporting:	The owner must keep records of all inspections, maintenance and repairs undertaken in the previous 24 months. The records must be kept with the compliance schedule and as a minimum, include: <ul style="list-style-type: none"> • Details of any inspection, test or preventative maintenance carried out. Include dates, work undertaken, faults found, remedies applied, and the person who performed the work. 		

SS 12.1 - Audio Loops

	<ul style="list-style-type: none">• A Form 12A provided by an IQP annually
--	--

The information above is used to help generate the compliance schedule. If you are unsure of how to fill in this form please consult an IQP who is registered for the system above.